

PURION 2501 H for water-disinfection

...is characterized by compact construction and a high degree of efficiency respecting to disinfection and energy consumption. The construction design follows laws, standards and regulations.



manufacturer	PURION® GmbH
type	PURION 2501 H
flow rate	10 m³/h
UVC-transmission	90% T ₁ cm
temperature of water	up to 90°C
reactor	stainless steel 1.4571
flanges external thread	R 1 1/2"
seal	FPM
dimensions (L x Ø in mm)	928 x 85
distance flanges	810 mm
weight	5,5 Kg
life time of lamps	8.000 h
number of lamps	1
dose	400 J/m²
max. working pressure	10 bar
protective system	IP 65
electrical connection	110-240 V50/60 Hz
total power	106 W
over current protection	10 A

UV Plant PURION 2501 H is equipped with a polished stainless steel reactor.
PURION 2501 H can be used to disinfect high temperature water specially to protect pool water against legionella. It's possible to disinfect pool water up to a volume of 50.000 l and for a transmission of at least 90% per cm.

The used UV-lamps are characterized by a long durability and a high degree of efficiency respecting to disinfection and energy consumption. The power supply can be carried out with 230 V/50 Hz

The compact construction design enables an easy replacement of the UV lamp at the end of their useful life. You don't need any tool. Also, replacement and cleaning of the quartz pipe can be arranged easily. UV disinfection is reached by floating the water through the reactor. Inside the reactor an UV lamp enclosed in a UV-C transparent quartz pipe is surrounded by the drinking water to be treated. The small distance of 27,5 mm between the quartz pipe and the inner surface of the reactor ensures optimal irradiation and therefore, optimal disinfection of the water.

This UV-plant is applied at:

Drinking water	•
Water of air conditioning	•
Disinfection of permeate	•
Pools	•
Aquariums	•
Fish ponds	•
Storm water of sewage plants	•
Pharmacy	•
Greenhouse	•
Water of domestic use	•

Advantages

- safe protection against legionella
- additional chemicals are not required for disinfection
- no change of hydro chemistry
- smell and taste of the water are not influenced by radiation
- less required space
- manageable maintenance, small operation expenses